

Taglia	Potenza	Giri/min.	Mandata	Portata (m³/h)													H (m) = Prevalenza	
				0	5	15	25	35	45	55	65	75	85	95	105	125		145
WSP 22	2,2 Kw	1450	Dn 80	11,0	10,8	10,3	9,7	9,1	8,3	7,6	6,8	5,9	5,1					
WSP 30	3 Kw	1450	Dn 80	12,6	12,2	11,4	10,7	10,1	9,4	8,7	8,0	7,2	6,4	5,4	4,4			
WSP 40	4 Kw	1450	Dn 80	15,9	15,3	14,3	13,5	12,8	12,0	11,2	10,4	9,4	8,4	7,4	6,5			
WSP 55	5,5 Kw	1450	Dn 100	14,0	13,8	13,3	12,8	12,3	11,8	11,3	10,8	10,3	9,8	9,2	8,7	7,7	6,8	
WSP 75	7,5 Kw	1450	Dn 100	16,7	16,4	15,9	15,3	14,8	14,3	13,9	13,5	13,2	12,9	12,6	12,1	10,7	7,9	

(dati e curve con acqua pulita)

